

REPORT DOCUMENTATION PAGE			Form Approved OMB NO. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comment regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE February 1996	3. REPORT TYPE AND DATES COVERED <i>Technical</i>		
4. TITLE AND SUBTITLE Semi-analytical Determination of Heat Transfer Coefficients in Nucleate Pool Boiling of Pure Liquids		5. FUNDING NUMBERS <i>DAAH04-95-1-0250</i>		
6. AUTHOR(S) Sharma, Parashu R., Lee, Angela, and Harrison, Tameka		8. PERFORMING ORGANIZATION REPORT NUMBER		
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Grambling State University Department of Mathematics and Computer Science Carver Hall, Room # 137 GRAMBLING, LA 71245		10. SPONSORING / MONITORING AGENCY REPORT NUMBER <i>ARO 34157.26-MA-152</i>		
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army Research Office P.O. Box 12211 Research Triangle Park, NC 27709-2211		11. SUPPLEMENTARY NOTES The views, opinions and/or findings contained in this report are those of the author(s) and should not be construed as an official Department of the Army position, policy or decision, unless so designated by other documentation.		
12a. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution unlimited.		12 b. DISTRIBUTION CODE		
13. ABSTRACT (Maximum 200 words) In this work we have modified a semi-empirical correlation for evaluating heat transfer coefficients for a variety of liquids possessing different physico-thermal properties. The liquids under investigation were hydrocarbons and distilled water. Data were chosen for a wide range of heating surfaces, heat flux, and pressures. The correlation for heat transfer coefficient is based on two main factors contributing for heat removal from the surface. The correlation is: $h = \frac{2}{\sqrt{\pi}} \sqrt{k_1 c_1 \rho_1} \sqrt{f} + \frac{1}{6} \rho_v \lambda f D_b \frac{1}{\Delta T_w}$ The first factor includes removal of heat by transient heat conduction to, and subsequent replacement of, superheated layer around boiling sites. The second factor takes into account the latent heat transport during growth of vapor bubbles. The equations for bubble emission frequency, f were developed analytically. Laplace Equation was used for the bubble departure diameters. The correlation predicts boiling heat transfer data well for hydrocarbons and distilled water. * Work supported by Office of Naval Research and Army Research Office				
14. SUBJECT TERMS Pool Boiling, Heat Transfer in Two Phase		15. NUMBER OF PAGES 25		
		16. PRICE CODE		
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT UL	

Semi-Analytical Determination of Heat Transfer Coefficients in Nucleate Pool Boiling of Pure Liquids*

**Angela Lee, Tameka Harrison
&
Parashu Sharma**

Grambling State University

February 2, 1996

***Work Supported by Office of Naval Research
and Army Research Office**

19970213 028

INTRODUCTION

This work attempts to modify the correlation earlier developed by Blöchl [1] for nucleate pool boiling heat transfer. We have developed the expressions for bubble emission frequency and tested this correlation at atmospheric and subatmospheric pressures for pure liquids. An analytical correlation for nucleate pool boiling should include the underlying mechanism of boiling heat transfer. Proper consideration should be given to the various heat transport factors responsible for removing the heat from the heat transfer surface in a boiling heat transfer process.

ANALYSIS:

The correlation is based on two main factors which contribute the removal of heat from the heat transfer surface.

The first factor suggested by Mikic and Rohsenow [2] postulates that the main mechanism of heat transfer in nucleate boiling is transient heat conduction to, and subsequent replacement of, superheated layer around boiling sites.

The second factor comes during the growth of vapor bubbles and their subsequent departure. Rallis and Jawurek [3] and Paul and Abdel-Khalik [4] have suggested that the latent heat transport plays a considerable role for the removal of heat from the heat transfer surface.

CORRELATION

$$(h)_{\text{pred}} = \frac{2}{\sqrt{\pi}} \sqrt{k_l c_l \rho_l} \sqrt{f} + \frac{1}{6} \rho_v \lambda f D_b \frac{1}{\Delta T_w}$$

The first factor represents the part of the heat removed due to conduction heat transfer from the surface to the adjacent liquid layer. When the sufficient degree of superheat is reached the bubbles start nucleating on the surface. It is believed that a larger portion of heat is removed because of this conduction process in the vicinity of the wall.

The removal of heat by this conduction process can be taken into account by the product of thermal accommodation factor (given by the product of thermal conductivity, specific heat, and density of boiling liquid and taking the square root of this product) and square root of bubble emission frequency.

The correlations for bubble emission frequency were earlier developed and presented in Louisiana Academy of Science Meeting by Terrell Ford. The same correlations are used in this work to calculate the value of heat transfer coefficient.

The equations for the bubble emission frequency for different ranges of Jakob numbers are:

$$f = \frac{1}{\frac{[133.3/P]^2 [\sigma/(\rho_l - \rho_v)g]}{\pi \alpha_l Ja^2} + \frac{0.867}{\alpha_l} \left[\frac{k_l \Delta T_w}{q_w} \right]^2}$$

for $Ja \leq 100$

$$f = \frac{1}{\frac{[133.3/P]^2 [\sigma/(\rho_l - \rho_v)g]}{25 \alpha_l Ja^{3/2}} + \frac{0.867}{\alpha_l} \left[\frac{k_l \Delta T_w}{q_w} \right]^2}$$

for $Ja > 100$

where $Ja = \frac{C_l \rho_l \Delta T_w}{\rho_v \lambda}$

The second factor represents the part of the heat removed by latent heat transport during the formation of the vapor bubbles until their departure. The quantity $\frac{1}{6} \rho_v \lambda f D_b \frac{1}{\Delta T_w}$ reflects this portion of heat transfer coefficient. The D_b is the diameter of the bubble at the time of departure and ΔT_w is the degree of wall superheat.

RESULTS

Heat transfer coefficients were calculated using this correlation for the data of Sharma. The predicted values of heat transfer coefficient were compared with the experimental values. The correlation predicted the data remarkably well within 10 per cent.

The study also reveals the effect of heat flux and pressure on bubble emission frequency and bubble departure diameter. Bubble frequency is the strong function of heat flux. It increases with increase in heat flux. Bubble frequency also is a function of pressure. An increase in pressure shows increase in frequency in bubble emission. The calculations also reflect the effect of pressure on bubble departure diameter. The bubble departure diameters decrease with increase in pressure.

CONCLUSIONS


Following conclusions can be drawn from this investigation:

1. Heat transfer rates in nucleate pool boiling are contributed by both conduction and latent heat transport. The conduction heat transfer plays more significant role.
2. The data correlates very well with the experimental data.
3. The study also reveals the effect of heat flux and pressure on bubble frequency and departure diameter. The frequency is a strong function of heat flux and also increases with increase in pressure while the bubble departure diameter decreases with increase in pressure.

REFERENCES

1. Blöchl, R. " Zum Einfluß der Oberflächenstruktur unterschiedlich bearbeiteter Heizflächen auf die Wärmeübertragung beim Blasensieden", Diss., Universität Karlsruhe (TH), 1986.
2. Mikic, B.B. and Rohsenow, W.M., " A new correlation of pool-boiling data including the effect of heating surface characteristics", Trans. ASME, Ser. C, J. Heat Transfer, pp 245-250 (1969).
3. Rallis, C.J. and Jawurek, H.H., " Latent heat transport in saturated nucleate boiling", Int. J. Heat Mass Transfer, Vol.7, pp1051-1068 (1964).
4. Paul, D. D. and Abdel-Khalik S. I., " A statistical analysis of saturated nucleate boiling along a heated wire", Int. J. Heat Mass Transfer, Vol. 25, No. 8, pp.509-518 (1982)
5. Sharma, P.R., Heat Transfer Studies in Pool Boiling of Liquids", Ph.D. Thesis, University of Roorkee, Roorkee (1977)

Exptl Data for Water at 98.44 kPa vs Data by Present Analysis



Report Created: 03-22-1995 11:45:00 AM

Linear Best Fit Curve

Pts Plotted = 7

Offscale Pts = 0

Regression Equation:

$$Y = 1.26898 X + (-602.501)$$

Correlation Coefficient = .996903


Std. Error about Regression Line = 151.806

t Statistic (Hypothesis: Slope=0) = 28.3435

X-axis file: DW_98.44_hpred_NC

Y-axis file: DW_98.44_hexptl

Exptl Data for Water at 66.65 kPa vs Data by Present Analysis



Report Created: 03-22-1995 2:57:04 PM

Linear Best Fit Curve

Pts Plotted = 6 Offscale. Pts = 0

Regression Equation:

$$Y = .78328 X + (665.974)$$

Correlation Coefficient = .985499


Std. Error about Regression Line = 200.036

t Statistic (Hypothesis: Slope=0) = 11.6159

X-axis file: DW_66.65_hpred_NC

Y-axis file: DW_66.65_hexptl

Exptl Data for Water at 47.32 kPa vs Data by Present Analysis



Report Created: 03-22-1995 3:11:52 PM

Linear Best Fit Curve

Pts. Plotted = 6 Offscale Pts = 0

Regression Equation:

$$Y = .936071 X + (351.551)$$

Correlation Coefficient = .99613


Std. Error about Regression Line = 115.655

t Statistic (Hypothesis: Slope=0) = 22.6673

X-axis file: DW_47.32_hpred_NC

Y-axis file: DW_47.32_hexptl

Exptl Data for Water at 11.33 kPa vs Data by Present Analysis



Report Created: 03-22-1995 3:27:57 PM

Linear Best Fit Curve

Pts Plotted = 5 Offscale Pts = 0

Regression Equation:

$$Y = 1.35074 X + (210.327)$$

Correlation Coefficient = .993605


Std. Error about Regression Line = 109.362

t Statistic (Hypothesis: Slope=0) = 15.2412

X-axis file: DW_11.33_hpred_NC

Y-axis file: DW_11.33_hexptl

Exptl Data for Methanol at 98.64 kPa vs Data by Present Analysis



Report Created: 03-22-1995 3:35:17 PM

Linear Best Fit Curve

Pts Plotted = 6 Offscale Pts = 0

Regression Equation:

$$Y = .907214 X + (93.6134)$$

Correlation Coefficient = .999896


Std. Error about Regression Line = 9.41357

t Statistic (Hypothesis: Slope=0) = 138.589

X-axis file: ML_98.64_hpred_NC

Y-axis file: ML_98.64_hexptl

Exptl Data for Methanol at 79.98 kPa vs Data by Present Analysis



Report Created: 03-22-1995 3:44:38 PM

Linear Best Fit Curve

Pts Plotted = 6

Offscale Pts = 0

Regression Equation:

$$Y = 1.07008 X + (-169.078)$$

Correlation Coefficient = .999788


Std. Error about Regression Line = 14.0147

t Statistic (Hypothesis: Slope=0) = 97.1241

X-axis file: ML_79.98_hpred_NC

Y-axis file: ML_79.98_hexptl

Exptl Data for Methanol at 66.65 kPa vs Data by Present Analysis



Report Created: 03-22-1995 3:52:43 PM

Linear Best Fit Curve

Pts Plotted = 6 Offscale Pts = 0

Regression Equation:

$$Y = 1.0082 X + (-130.084)$$

Correlation Coefficient = .999784


Std. Error about Regression Line = 13.1456

t Statistic (Hypothesis: Slope=0) = 96.1457

X-axis file: ML_66.65_hpred_NC

Y-axis file: ML_66.65_hexptl

Exptl Data for Methanol at 41.32 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:05:23 PM

Linear Best Fit Curve

Pts Plotted = .6

Offscale Pts = .0

Regression Equation:

$$Y = .917809 X + (-134.101)$$

Correlation Coefficient = .988162


Std. Error about Regression Line = 85.4739

t Statistic (Hypothesis: Slope=0) = 12.8824

X-axis file: ML_41.32_hpred_NC

Y-axis file: ML_41.32_hexptl

Exptl Data for Methanol at 27.99 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:11:12 PM

Linear Best Fit Curve

Pts Plotted = 5 Offscale Pts = 0

Regression Equation:

$$Y = .889673 X + (-151.658)$$

Correlation Coefficient = .999616


Std. Error about Regression Line = 12.4373

t Statistic (Hypothesis: Slope=0) = 62.5031

X-axis file: ML_27.99_hpred_NC

Y-axis file: ML_27.99_hexptl

Exptl Data for Isopropanol at 97.98 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:17:34 PM

Linear Best Fit Curve

Pts Plotted = 7 Offscale Pts = 0

Regression Equation:

$$Y = 1.13657 X + (-225.507)$$

Correlation Coefficient = .998991


Std. Error about Regression Line = 34.8752

t Statistic (Hypothesis: Slope=0) = 49.7367

X-axis file: IL_97.98_hpred_NC

Y-axis file: IL_97.98_hexptl

Exptl Data for Isopropanol at 67.28 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:36:51 PM

Linear Best Fit Curve

Pts Plotted = 7

Offscale Pts = 0

Regression Equation:

$$Y = 1.02147 X + (-16.0477)$$

Correlation Coefficient = .993438


Std. Error about Regression Line = 72.1817

t Statistic (Hypothesis: Slope=0) = 19.4231

X-axis file: IL_67.28_hpred

Y-axis file: IL_67.28_hexptl

Exptl Data for Isopropanol at 54.65 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:42:12 PM

Linear Best Fit Curve

Pts Plotted = 7 Offscale Pts = 0

Regression Equation:

$$Y = 1.05855 X + (-143.265)$$

Correlation Coefficient = .999589


Std. Error about Regression Line = 18.0339

t Statistic (Hypothesis: Slope=0) = 77.962

X-axis file: IL_54.65_hpred_NC

Y-axis file: IL_54.65_hexptl

Exptl Data for Isopropanol at 29.33 kPa vs Data by Present Analysis



Report Created: 03-22-1995 4:56:00 PM

Linear Best Fit Curve

Pts Plotted = 6 Offscale Pts = 0

Regression Equation:

$$Y = 1.04512 X + (-223.397)$$

Correlation Coefficient = .999795


Std. Error about Regression Line = 10.7979

t Statistic (Hypothesis: Slope=0) = 98.7593

X-axis file: IL_29.33_hpred_NC

Y-axis file: IL_29.33_hexptl

Exptl Data for Ethanol at 98.18 kPa vs Data by Present Analysis



Report Created: 03-22-1995 5:00:58 PM

Linear Best Fit Curve

Pts Plotted = 8

Offscale Pts = 0

Regression Equation:

$$Y = 1.12812 X + (-83.1872)$$

Correlation Coefficient = .998043


Std. Error about Regression Line = 39.8133

t Statistic (Hypothesis: Slope=0) = 39.0937

X-axis file: EL_98.18_hpred_NC

Y-axis file: EL_98.18_hexptl

Exptl Data for Ethanol at 84.85 kPa vs Data by Present Analysis



Report Created: 03-22-1995 5:07:17 PM

Linear Best Fit Curve

Pts Plotted = 7

Offscale Pts = 0

Regression Equation:

$$Y = 1.20399 X + (-363.563)$$

Correlation Coefficient = .996072


Std. Error about Regression Line = 45.3411

t Statistic (Hypothesis: Slope=0) = 25.1532

X-axis file: EL_84.85_hpred_NC

Y-axis file: EL_84.85_hexptl

Exptl Data for Ethanol at 71.32 kPa vs Data by Present Analysis



Report Created: 03-22-1995 5:12:19 PM

Linear Best Fit Curve

Pts Plotted = 6

Offscale Pts = 0

Regression Equation:

$$Y = 1.17681 X + (-298.705)$$

Correlation Coefficient = .997439


Std. Error about Regression Line = 50.9419

t Statistic (Hypothesis: Slope=0) = 27.894

X-axis file: EL_71.32_hpred_NC

Y-axis file: EL_71.32_hexptl

Exptl Data for Ethanol at 44.65 kPa vs Data Present Analysis



Report Created: 03-22-1995 5:18:08 PM

Linear Best Fit Curve

Pts Plotted = 6

Offscale Pts = 0

Regression Equation:

$$Y = 1.17696 X + (-320.825)$$

Correlation Coefficient = .997005


Std. Error about Regression Line = 50.4182

t Statistic (Hypothesis: Slope=0) = 25.785


X-axis file: EL_44.65_hpred_NC

Y-axis file: EL_44.65_hexptl


f vs q for Methanol (Sharma) at 98.64 & 27.99 kPa



f vs q for Isopropanol(Sharma) at 80.77&67.28 kPa



Db vs P for Ethanol (Sharma)



Report Created: 03-23-1995 5:07:46 PM

Power Curve Fit
Pts Plotted = 6

Offscale Pts = 0

Regression Equation:
 $Y = 1.8345 X^{-3.75544E-02}$

Correlation Coefficient = -.997546

X-axis file: EL_p_X_PRS
Y-axis file: EL_Db_Y_PRS